



PRODUCT SPECIFICATION

CGAS-SC-CO-2AO-DV Self Contained Controller

Self Contained Controller with Electrochemical Carbon Monoxide (CO) Sensor (standard range)

Dimensions:	8 x 6.07 x 3.16 in (20.3 x 15.4 x 8 cm) without optional splash guard (Option -S)
Size	
Weight	750 g / 1.65 lbs
Construction:	Black ABS / Polycarbonate blend, water/dust tight, corrosion resistant
Sensor: Type	Electrochemical
Life Span	Approximately 3 years (application dependent)
UL Listed	UL2075
Gases Detected:	Carbon Monoxide (CO)
Sensor Range:	0 – 200 ppm (standard)
System Power:	Low voltage: 16 – 30 VDC / 12 – 28 VAC, 50/60 Hz, 10W, Class 2 Line voltage: 100 – 240V AC +/-10%, 50/60 Hz, 10W, 1-phase
Operating Temperature:	0°C to +40°C (32°F to 104°F), -40°C (-40°F) with low temperature Option -LT
Operating Humidity:	15 to 95% non-condensing
Indicators:	LCD display 2 x 16 characters with LED panel indicating alarm status 1, 2 and 3 for any channel and FAULT
Output (user selectable):	Two analog outputs jumper selectable current or voltage BACnet® MS/TP (version 1 rev 14) RS-485, or Modbus® RTU (version 1.1b3) RS-485 Horn/strobe output terminal
Relay	2 internal SPDT dry contact relays, rated 5 amps @ 240 VAC
Audible Alarm	Standard: Internal buzzer, rated 76 dB @ 3 m (10 ft) Option -A: Side mounted buzzer, rated 90 dB @ 30 cm (1 ft) Option -WA: Water tight, side mounted buzzer, rated 85 dB @ 60.96 cm (2 ft) User selectable Temporal 4 sound pattern
Minimum Detection:	2 ppm (with regular calibration maintenance of sensor)
Accuracy:	<1ppm
Repeatability:	< ±3% CO equivalent
Sensitivity Drift:	<5 % per year
Response Time:	<30 seconds
Resolution:	Display resolution 1 ppm Sensor resolution: <1 ppm
Warm Up Time:	3 minutes after power up (to full operation)
Cross Sensitivity:	H2@1000 ppm = <35ppm, NO@50ppm = <10ppm, C2H6O@200ppm = <1ppm, CL2@15 = <1ppm, C2H4@100ppm = <96ppm, C2H2@100ppm = <90ppm
Safety:	Automatic resetting thermal overload fuse (reset capabilities to 500 times)
Wiring:	Low voltage: 24 VDC or 24 VAC 2-conductor, 14 - 18 AWG stranded within conduit Line voltage: VAC 3-conductor (Line, Neutral, Protective Earth Ground), 18 AWG stranded within conduit Network wiring (daisy-chain): 4-conductor, 16 AWG, stranded within conduit
Sensor Mounting:	Breathing Zone - slightly lighter than air 4 to 6 ft (1.2 to 1.8 m) from finished floor
Monitoring Area:	7,000 to 10,000 ft² / 464 to 929 m² 40 to 56 foot / 12 to 17 meter radius, application dependent
Suggested Alarm Setpoints	Low Alarm: 25 ppm / Mid Alarm: 50 ppm / High Alarm: 100 ppm
Certifications:	CSA-C22.2 No 61010-1, UL 61010-1 (Edition 3)
(tested to)	RoHS compliant circuit boards Listed by BTL



CGAS-SC-CO-2AO-DV Self Contained Controller

This device complies with part 15 of the FCC Rules

Note:

Never install gas detectors in the direct path of moving air
Replacement for the DCC-A-TCO

Conditions Affecting Electrochemical Sensors:

- Typically designed to operate between -10°C and +50°C, do not exposed to extreme temperatures for prolonged periods of time. Repeated or prolonged exposure to temperatures like 60-65°C / 140-149 can lead to evaporation of the electrolyte and shifts in baselines readings.
- Do not expose to high moisture for extended periods of time.
- Prolonged exposure to extremely high gas concentrations can compromise sensor performance.
- Paint fumes, cleaning products, dust, sand, water, insects can reduce lifespan and compromise performance. Avoid exposure to high concentrations of solvent vapours both during storage and operation.
- Before initial use after production may be stored at room temperature ideally at 20°C / 68°F and 60%RH or preferably in the fridge for up to 6 months. Beyond this period, the sensor performance is likely to deteriorate, such as with longer response time and lower sensitivity regardless of whether sensor has been used or not.
- The more exotic gases (chlorine, ozone etc.) tend to have shorter life spans than the more common gases (CO, nitrogen dioxide)
- Install gas detector vertically so the display is over top of the sensor vent and device is flat against a wall or column. Never install gas detectors in the direct path of moving air.

Rev: 2024-04